

EXHIBIT 55

New Hampshire State Building Code Proposed Amendment

PROPOSED AMENDMENT TO THE 2009 IECC CODE

Current Code language:

IECC Table 402.1.1 Insulation and Fenestration Requirements by Component

Proposed code language:

Add footnote "k" to the Mass Wall R-value column of IECC TABLE 402.1.1
Insulation and Fenestration Requirements by Component

Footnote "k" to read as follows:

^k Log walls complying with ICC400 and with a minimum average wall thickness of 5" or greater shall be permitted in Zones 5-8 when overall window glazing is .31 U-factor or lower, minimum heating equipment efficiency of 90 AFUE (gas) or 84 AFUE (oil), and all other component requirements are met.